

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014460-R1
DATE: 07/10/2019
CERTIFICATION PROGRAM: Fire
COMPANY: G-M Wood Prod
CODE: 2136-1
REVISION DATE: 08/10/2023
EXPIRATION DATE: 07/31/2030

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
G-M Wood Products, Inc. 531 Clay Street Newaygo, MI 49337	Qingdao Sea Nova Building Profiles Model "OF White" 20 Minute Category C-Proprietary PVC Clad Composite Door Frames Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations Maximum Size: W-49.69" x H-96.85" Minimum Jamb Depth: 4.13"

SPECIFICATION	PRODUCT RATING
CAN4 S104(2015) NFPA 252(2017) UL 10C(2016) UL 10B (2015)	20 Minute-With Hose Stream Neutral or Positive Pressure Category C- Proprietary Frame

TEST REPORT

Intertek Test Report No(s): 190228009SHF-001

A handwritten signature in black ink, appearing to be "S.M.", written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124
nami@namiinc.com