

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014474-R1  
**DATE:** 08/06/2019  
**CERTIFICATION PROGRAM:** Fire  
**COMPANY:** Lumbermen's  
**CODE:** 1021-1  
**REVISION DATE:** 06/22/2023  
**EXPIRATION DATE:** 08/31/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	
<b>Lumbermen's Incorporated</b> <b>8715 Byron Commerce Drive Southwest</b> <b>Byron Center, MI 49315</b>	<b>Therma Tru 20 Minute Fiberglass Door</b> <b>w/Proprietary Foam Core</b> <b>(Simulated, Flush or Shaker Panel Type)</b>  Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations  <b>Single Door Maximum Size: 36" x 96"</b> <b>Shaker Single Door Maximum Size: 36" x 80"</b>  <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>UL 10C (2016)</b> <b>NFPA 252 (2012)</b>	<b>20 Minute-without Hose Stream</b> <b>Positive Pressure</b> <b>Category B- Additional Edge Sealing</b> <b>Required</b>

TEST REPORT
<b>Intertek Test Report No: 103875182MID-007</b>

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122