

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014497-R1
DATE: 09/16/2019
CERTIFICATION PROGRAM: Fire
COMPANY: Orepac
CODE: 1234-1
REVISION DATE: 08/01/2023
EXPIRATION DATE: 09/30/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | |
|--|---|
| Orepac Building Products, Inc. 30160 SW Orepac Avenue Wilsonville, OR 97070 | Therma Tru 20 Minute Fiberglass Door w/Proprietary Foam Core (Simulated, Flush or Shaker Panel Type) Manufacture Specific Fire Door Frames for Single Swing Installation in 20 Minute Locations Single Door Maximum Size: 36" x 96" Shaker Single Door Maximum Size: 36" x 80" Minimum Thickness: 1-3/4" |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| UL 10C (2016) NFPA 252 (2012) | 20 Minute-without Hose Stream Positive Pressure Category B- Additional Edge Sealing Required |

| TEST REPORT |
|--|
| Intertek Test Report No: 103875182MID-007 |

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com