## **NOTICE OF PRODUCT CERTIFICATION**

	NUA14550 D1
CERTIFICATION NO:	<u>NI014578-R1</u>
DATE:	<u>12/12/2019</u>
<b>CERTIFICATION PROGRAM:</b>	Fire
<b>COMPANY:</b>	TNT Door
CODE:	<u>2610-1</u>
<b>REVISION DATE:</b>	<u>10/30/2023</u>
<b>EXPIRATION DATE:</b>	12/31/2025
	CERTIFICATION PROGRAM: COMPANY: CODE: REVISION DATE:

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
TNT Door & Millwork, Inc.	Lynden 20 Minute Profiled
11400 West Executive Drive, Suite 8	Particleboard Core Fire Door Assembly
Boise, ID 83713	Manufacturer Specific Fire Doors for Single and Double Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw for Singles 3-Point Latching Hardware Required for Doubles Single & Double Swing Only
	Single Maximum Size: 3'0" x 8'0" Single Maximum Size: 3'6" x 7'0" Double Maximum Size: 6'0" x 7'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008)(2012)	20 Minute-Positive Pressure
UL 10C (2001)(2009)	With Hose Stream
UL 10B (2008)(2009)	Category B Door-Additional Edge Seal Required
<b>UBC Standard 7-2 (1997)</b>	(unless specified in individual manufacturer's listing)
CAN/ULC S104 (1980 (R1985))	For Use in ANSI-A155/UL-63 16-Gauge Steel Frame (or may also be installed in Category C-Proprietary in accordance
	with individual manufacturer's listing)

## **TEST REPORT**

Intertek Test Report No: 3141706COQ-001

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 nami@namiinc.com