

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014579-R1  
**DATE:** 12/12/2019  
**CERTIFICATION PROGRAM:** Fire  
**COMPANY:** TNT Door  
**CODE:** 2610-1  
**REVISION DATE:** 10/30/2023  
**EXPIRATION DATE:** 12/31/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>TNT Door &amp; Millwork, Inc.</b> <b>11400 West Executive Drive, Suite 8</b> <b>Boise, ID 83713</b>	<b>Lynden 20 Minute L20SP</b> <b>Wood Core Fire Door Assembly</b>  Manufacturer Specific Fire Doors for Single and Double Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw for Singles 3/4" Minimum Latch Throw for Double Single & Double Swing Only  Single Maximum Size: 4'0" x 9'0" Single Maximum Size: 3'6" x 10'0" Double Maximum Size: 8'0" x 9'0" Double Egress Maximum Size: 8'0" x 8'0" Dutch Door: 4'0" x 8'0" Door w/Transom Maximum Size: 4'0" x 10'0" Transom Maximum Size: 3'0" x 3'4" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2008)(2012)</b> <b>UL 10C (2001)(2009)(2016)</b> <b>UL 10B (2008)(2009)</b> <b>UBC Standard 7-2 (1994)(1997)(2015)</b> <b>CAN/ULC S104 (1985)(2010)</b> <b>CSFM 43.7</b>	<b>20 Minute-Positive Pressure</b> <b>With Hose Stream</b> <b>Category B Door-Additional Edge Seal Required</b> (unless specified in individual manufacturer's listing) <b>For Use in Category C-Standard Frame</b> (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)
TEST REPORT	
Intertek Test Report No: 491-7972/3052139/3060684/3075954/3157236/103140421	

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)

