

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014758-R1
DATE: 03/23/2020
CERTIFICATION PROGRAM: Fire
COMPANY: Stier Supply
CODE: 1728-1
REVISION DATE: 09/24/2024
EXPIRATION DATE: 03/31/2028

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Stier Supply Company 303 Bellinger Lane Gaston, SC 29053	Crest Doors 6-Panel Embossed Steel Fire Door Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Single Maximum Size: 3'0" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
ASTM E152-81a UL 10B (1997)(2009) NFPA 252 (1999)	20 Minute-Neutral Pressure Without Hose Stream Category A - No Additional Edge Sealing System Required

TEST REPORT
Intertek Test Report No: 3125633

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shel", written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2023