

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014924-R1
DATE: 08/07/2020
CERTIFICATION PROGRAM: Fire
COMPANY: Bjornstad Const.
CODE: 2644-1
REVISION DATE: 08/31/2023
EXPIRATION DATE: 08/31/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Bjornstad Construction Company 1240 Texan Trail, Suite 102 Grapevine, TX 76051	Jeld Wen 20 Minute Neutral Pressure Steel Side-Hinged Door Assembly Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Single Swing Maximum Size: 3'6" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008) UL 10B (2009) UBC 7-2 (1994)	20 Minute-Neutral Pressure Without Hose Stream Category B - Additional Edge Sealing Required

TEST REPORT
Intertek Test Report No: WHI 495-0897, 100108677COQ-001, 100211525COQ-001, 100237214MID-001, 100754937MID-001

Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com