

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014956-R1  
DATE: 09/04/2020  
CERTIFICATION PROGRAM: Fire  
COMPANY: JELD-WEN  
CODE: 1822-1  
REVISION DATE: 05/10/2022  
EXPIRATION DATE: 09/30/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>Jeld Wen 45-60 Minute</b> <b>Profiled Core Side-Hinged Door</b> <b>w/Universal or Universal HD Core</b>  Manufacturer Specific Fire Doors for Single & Double Swing Installation in 45-60 Minute Locations  1/2" Minimum Latch Throw Single & Double Swing Only (Double Egress Not Allowed)  <b>Single Maximum Size: 3'6" x 7'0"</b> <b>Single Maximum Size: 3'0" x 8'0"</b> <b>Double Maximum Size: 7'0" x 7'0"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>UL 10(c) (2009/2016)</b> <b>CAN/ULC-S104 (2015)</b> <b>NFPA 252 (2012)</b>	<b>45-60 Minute-Positive Pressure w/Hose Stream</b> <b>Category A Door-No Additional Edge Seal</b> <b>Required</b> <b>For Use in 16 &amp; 18 Gauge Steel Frames</b> (or may also be installed in Category C or Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
<b>Intertek Test Report No: G103003006MID-008, WHI-495-1314</b> <b>NAMI Waiver of Retest: W-2028</b>

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)