NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014960-R2

DATE: 09/04/2020

CERTIFICATION PROGRAM: Fire

COMPANY: JELD-WEN

CODE: <u>1822-1</u>

REVISION DATE: <u>10/31/2023</u> **EXPIRATION DATE:** <u>09/30/2024</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN	20 Minute Positive Pressure
3737 Lakeport Boulevard	Molded Simulated Panel Side-Hinged
Klamath Falls, OR 97601	Side-Hinged Door Assembly
	Manufacturer Specific Fire Doors for Single Swing or Standard Pairs Installation in 20 Minute Locations
	1/2" Minimum Latch Throw Single Swing or Standard Pairs Only
	Single Swing Maximum Size: 3'0" x 8'0" Standard Pairs Maximum Size: 6'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (1999) UL 10(b) (2009) CAN4-S104 (1985)(2010) UL 10(c) (2009)	20 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT

Intertek Test Report No: 3192291COQ-005, 100211525COQ-001, 100553244COQ-002, 100581395MID-001, 101432263COQ

NAMI Waiver of Retest: W-2063/W-2090

Administrator's Signature:



NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124/nami@namiinc.com