NOTICE OF PRODUCT CERTIFICATION

	CERTIFICATION NO:	NI014961-R1
1065 ACCHEDITED AD	DATE:	<u>09/04/2020</u>
Salle Contraction of the	CERTIFICATION PROGRAM:	Fire
NAMI NAMI	COMPANY:	JELD-WEN
(rel CPD) rel	CODE:	<u>1822-1</u>
CED CEMENT INSTITUT	REVISION DATE:	<u>03/28/2023</u>
SATIFIED PRODUC	EXPIRATION DATE:	09/30/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

PRODUCT DESCRIPTION	
Jeld Wen Premium 20 Minute Neutral	
Pressure Fiberglass Side-Hinged Door	
Assemblies	
Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations	
1/2" Minimum Latch Throw Single Swing and Pairs Allowed	
Single Swing Maximum Size: 3'0" x 8'0" Minimum Thickness: 1-3/4"	
Pairs Maximum Size: 6'0" x 6'8" Minimum Thickness: 1-3/4"	

SPECIFICATION

NFPA 252 (2008) UL 10B (2008/2009) CAN/ULC S104 (2010)

PRODUCT RATING

20 Minute-Neutral Pressure With Hose Stream Category B - Additional Edge Sealing Required

TEST REPORT

Intertek Test Report No: 3091617, 3145981MID-005b, 3153159MID-007, 100211525COQ-001 NAMI Waiver of Retest: W-2063

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 nami@namiinc.com