

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014986-R1
DATE: 09/24/2020
CERTIFICATION PROGRAM: Fire
COMPANY: Starlink
CODE: 2681-1
REVISION DATE: 03/21/2022
EXPIRATION DATE: 07/31/2031

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Starlink Building Supply, Inc. 4982 4th Street Irwindale, CA 91706	Series " 200PP" Single Leaf Fire Proof Fiberglass Side Hinged Door Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 908mm x 2413mm Minimum Thickness: 44.5mm

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012) UL 10(b) (2009) UBC Standard 7-2 (1997) UL 10(c) (2009)	20 Minute-Positive Pressure 20 Minute-Neutral Pressure Without Hose Stream Category B Door-Additional Edge Seal Required For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: 170410011SHF-BP-1

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/ nami@namiinc.com