## **NOTICE OF PRODUCT CERTIFICATION**



To verify that the "Notice of Product Certification" is valid, please visit <u>www.NAMICertification.com</u> to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS         | PRODUCT DESCRIPTION  |
|----------------------------------|--|
| North State Millwork Corporation | MMPA 20 Minute Category C  |
| 2708 West Raleigh Boulevard      | <b>Proprietary Wood Door Frames</b>  |
| Rocky Mount, NC 27803            |  |
|                                  | Manufacture Specific Fire Door Frames for Single<br>Swing Only Installation in 20 Minute Locations |
|                                  | Single Door Maximum Size: 3'6" x 7'0"  |
|                                  | Minimum Thickness: 3-3/4"  |

| SPECIFICATION                                      | PRODUCT RATING   |
|--|--|
| UL 10C (1998)<br>UBC Standard 7-2 (1997)           | 20 Minute-With & Without Hose Stream<br>Neutral Pressure |
| UBC Standard 7-2 (1997)<br>UBC Standard 7-2 (1994) | Category C- Proprietary Frame                            |
|  |  |

## **TEST REPORT**

Warnock Hersey Test Report No: WHI-495-0509 Intertek Test Report No(s): 3746699, 8772599, 3028781, 3035264, 3048460 Priest & Assoc. Engineering Evaluation No: 10260 NAMI Waiver of Retest: W-1747

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC. 4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124/ Fax: (804) 684-5122