

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015097-R1
DATE: 11/30/2020
CERTIFICATION PROGRAM: Fire
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 03/28/2023
EXPIRATION DATE: 11/30/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	20-Minute Foam-Filled Steel Fire Door Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012/2017) UL 10B (2009/2015)	20 Minute-Neutral Pressure Without Hose Stream

TEST REPORT
Intertek Test Report No: 100108677COQ-001, G100108677, G100237215, G100211525, G100754937, G102772178 NAMI Waiver of Retest: W-2063

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com