NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI015097-R2**
DATE:	**11/30/2020**
CERTIFICATION PROGRAM:	**Fire**
COMPANY:	**JELD-WEN**
CODE:	**1822-1**
REVISION DATE:	**11/04/2024**
EXPIRATION DATE:	**11/30/2034**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN **3737 Lakeport Boulevard** **Klamath Falls, OR 97601**	**20-Minute Foam-Filled** **Steel Fire Door** Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only **Maximum Size: 3'0" x 6'8"** **Minimum Thickness: 1-3/4"**

SPECIFICATION	PRODUCT RATING
NFPA 252 (2012/2017) **UL 10B (2009/2015)**	**20 Minute-Neutral Pressure** **Without Hose Stream**

TEST REPORT
Intertek Test Report No: 100108677COQ-001, G100108677, G100237215, G100211525, G100754937, G102772178 **NAMI Waiver of Retest: W-2063**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com