


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012709
DATE: 07/07/2015
CERTIFICATION PROGRAM: Fire
COMPANY: Can-Save
CODE: 1347-1
EXPIRATION DATE: 07/31/2019

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Can-Save 411 Bayview Avenue Barrie, ON L4N 8Y2	Jeld Wen 20 Minute Neutral Pressure Steel Side-Hinged Door Assembly Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Single Swing Maximum Size: 3'6" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (2008) UL 10B (2009) UBC 7-2 (1994)	20 Minute-Neutral Pressure Without Hose Stream Category B - Additional Edge Sealing Required

TEST REPORT
Intertek Test Report No: WHI 495-0897, 100108677COQ-001, 100211525COQ-001, 100237214MID-001, 100754937MID-001

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122