

NOTICE OF PRODUCT CERTIFICATION



Company: ODL/Wester Reflections
 215 East Roosevelt Avenue
 Zeeland, MI 49464

Certification No.: NI010685-R1 Pg 1 of 4
Certification Date: 06/30/2011
Expiration Date: 06/30/2025
Revision Date: 07/30/2015

Product: Impact Resistant “Allen Aluminum Lite Frames”
IG Glazing: Laminate-1/8” Annealed Glass/0.090” Saflex by Solutia/1/8” Annealed Glass/1/8” Tempered Glass

The “Notice of Product Certification” is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI’s Certified Product Listing at www.Namicertification.com. NAMI’s Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
O Single	N/A	Glazed	3’2” x 8’1”	+80/-80 psf	N/A	Yes	TEL 01310361 Test Specification: ASTM E1886/1996-06 Wind Zone 4-Missile Level D Plastpro Fixed Fiberglass Door Lip Lite Frame-2’0” x 6’10”/DLO: 1’9” x 6’8” IG w/Boxed Aluminum Spacer System
O Single	N/A	Glazed	3’2” x 8’1”	+80/-80 psf	12.0 psf	Yes	TEL 01310320 Test Specification: ASTM E283-04/E330-02/E331-00 ASTM E1886/1996-06 Wind Zone 4-Missile Level D JELD-WEN Fixed Steel Door Lip Lite Frmae-2’0” x 6’10”/DLO: 1’9” x 6’8” IG w/Boxed Aluminum Spacer System
O Single	N/A	Glazed	3’2” x 8’1”	+80/-80 psf	N/A	Yes	TEL 01310360 Test Specification: TAS 201/203-94 Large Missile Impact Rated Plastpro Fixed Fiberglass Door Lip Lite Frame-2’0” x 6’10”/DLO: 1’9” x 6’8” IG w/Boxed Aluminum Spacer System

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
 Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: _____

A handwritten signature in black ink, appearing to be 'S.M.D.', written over a horizontal line.

NOTICE OF PRODUCT CERTIFICATION



Company: ODL/Wester Reflections
215 East Roosevelt Avenue
Zeeland, MI 49464

Certification No.: NI010685-R1 Pg 2 of 4
Certification Date: 06/30/2011
Expiration Date: 06/30/2025
Revision Date: 07/30/2015

Product: Impact Resistant “Allen Aluminum Lite Frames”
IG Glazing: Laminate-1/8” Annealed Glass/0.090” Saflex by Solutia/1/8” Annealed Glass/1/8” Tempered Glass

The “Notice of Product Certification” is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI’s Certified Product Listing at www.Namicertification.com. NAMI’s Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
O Single	N/A	Glazed	3’2” x 8’1”	+80/-80 psf	12.0 psf	Yes	TEL 01310319 Test Specification: TAS 201/202/203-94 Large Missile Impact Rated JELD-WEN Fixed Steel Door Lip Lite Frame-2’0” x 6’10”/DLO: 1’9” x 6’8” IG w/Boxed Aluminum Spacer System
O Single	N/A	Glazed	3’2” x 8’1”	+80/-80 psf	12.0 psf	Yes	TEL 01310303 Test Specification: TAS 201/202/203-94 Large Missile Impact Rated JELD-WEN Fixed Steel Door Lip Lite Frame-2’0” x 6’10”/DLO: 1’9” x 6’8” IG w/Super Spacer
O Single	N/A	Glazed	3’2” x 8’1”	+80/-80 psf	12.0 psf	Yes	TEL 01310303 Test Specification: TAS 201/202/203-94 Large Missile Impact Rated Therma-Tru Fixed Fiberglass Door Lip Lite Frame-2’0” x 6’10”/DLO: 1’9” x 6’8” IG w/Intercept Spacer System
O Single	N/A	Glazed	3’2” x 8’1”	+80/-80 psf	12.0 psf	Yes	TEL 01310303 Test Specification: TAS 201/202/203-94 Large Missile Impact Rated Plastpro Fixed Fiberglass Door Lip Lite Frame-2’0” x 6’10”/DLO: 1’9” x 6’8” IG w/Decoseal Spacer System

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: _____

NOTICE OF PRODUCT CERTIFICATION



Company: ODL/Wester Reflections
 215 East Roosevelt Avenue
 Zeeland, MI 49464

Certification No.: NI010685-R1 Pg 3 of 4
Certification Date: 06/30/2011
Expiration Date: 06/30/2025
Revision Date: 07/30/2015

Product: Impact Resistant “Allen Aluminum Lite Frames”
IG Glazing: Laminated-1/8” Annealed Glass/0.090” Saflex by Solutia/1/8” Annealed Glass/1/8” Tempered Glass

The “Notice of Product Certification” is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI’s Certified Product Listing at www.Namicertification.com. NAMI’s Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
O Single	N/A	Glazed	3’2” x 8’1”	+66/-66 psf	9.9 psf	Yes	TEL 01310303 Test Specification: TAS 201/202/203-94 Large Missile Impact Rated JELD-WEN Fixed Fiberglass Door Lip Lite Frame-2’0” x 6’10”/DLO: 1’9” x 6’8” IG w/Super Spacer
O Single	N/A	Glazed	3’2” x 8’1”	+80/-80 psf	12.0 psf	Yes	TEL 01310304 Test Specification: ASTM E330-02/E331-00/E283-04/ ASTM E1886-06/E1996-06 Wind Zone 4-Missile Level D JELD-WEN Fixed Steel Door Lip Lite Frame-2’0” x 6’10”/DLO: 1’9” x 6’8” IG w/Super Spacer
O Single	N/A	Glazed	3’2” x 8’1”	+80/-80 psf	12.0 psf	Yes	TEL 01310304 Test Specification: ASTM E330-02/E331-00/E283-04/ ASTM E1886-06/E1996-06 Wind Zone 4-Missile Level D Therma-Tru Fixed Fiberglass Door Lip Lite Frame-2’0” x 6’10”/DLO: 1’9” x 6’8” IG w/Intercept Spacer System
O Single	N/A	Glazed	3’2” x 8’1”	+80/-80 psf	12.0 psf	Yes	TEL 01310304 Test Specification: ASTM E330-02/E331-00/E283-04/ ASTM E1886-06/E1996-06 Wind Zone 4-Missile Level D Plastpro Fixed Fiberglass Door Lip Lite Frame-2’0” x 6’10”/DLO: 1’9” x 6’8” IG w/Decoseal Spacer System

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: _____ 

NOTICE OF PRODUCT CERTIFICATION



Company: ODL/Wester Reflections
 215 East Roosevelt Avenue
 Zeeland, MI 49464

Certification No.: NI010685-R1 Pg 4 of 4
Certification Date: 06/30/2011
Expiration Date: 06/30/2025
Revision Date: 07/30/2015

Product: Impact Resistant “Allen Aluminum Lite Frames”
IG Glazing: Laminate-1/8” Annealed Glass/0.090” Saflex by Solutia/1/8” Annealed Glass/1/8” Tempered Glass

The “Notice of Product Certification” is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI’s Certified Product Listing at www.Namicertification.com. NAMI’s Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
O Single	N/A	Glazed	3’2” x 8’1”	+66/-66 psf	9.9 psf	Yes	TEL 01310304 Test Specification: ASTM E330-02/E331-00/E283-04/ ASTM E1886-06/E1996-06 Wind Zone 4-Missile Level D JELD-WEN Fixed Fiberglass Door Lip Lite Frame-2’0” x 6’10”/DLO: 1’9” x 6’8” IG w/Super Spacer

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
 Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: _____ 