

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010549-R1
DATE: 03/14/2011
CERTIFICATION PROGRAM: Structural
COMPANY: All Seasons
CODE: 217-1
REVISION DATE: 02/11/2016

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|---|
| All Seasons Door & Window, Inc. 28 Edgeboro Road East Brunswick, NJ 08816 | Series "A-200" Thermally-Broken Aluminum Tilt Double Hung Window Configuration: X/X Glazing: Insulating Glass (Tempered) Frame: W-1422mm(56") H-2311mm(91") Sash: W-1346mm(53") H-1137mm(44.75") |

| SPECIFICATION | PRODUCT RATING |
|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 | Class LC-PG60 1422 x 2311 (56 x 91)-H H-C60 1422 x 2311 (56 x 91)-H Design Pressure: ±2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.0 psf) |

Product Tested By: National Certified Testing Laboratories, Inc.
Report No: NCTL-110-13604-1
Expiration Date: January 31, 2025

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122