

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013044.01  
**DATE:** 03/14/2016  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** MQ Windows  
**CODE:** 1577-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>MQ Windows</b> <b>50 Rue Brissette</b> <b>Ste-Agathe Des Monts, Quebec J8C 1M4</b>	<b>"JS Series In-Swing</b> <b>Tilt/Turn Wood Window</b>  <b>Impact Resistant</b>  Configuration: XX Glazing: Laminate-3/16" Annealed Glass/ 0.090" Interlayer by Eastman Chemical/3/16" Heat Strengthened Glass or IG-Laminate-3/16" Annealed Glass/ 0.090" Interlayer by Eastman Chemical/3/16" Heat Strengthened Glass/5/32" Annealed Glass  Frame: W-1626mm(64") H-2134mm(84") Panel: W-800mm(31.5") H-2013mm(79.25")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure:</b> <b>+2873 Pa (60 psf)/-3352 Pa (70 psf)</b> <b>Large Missile Impact Rated</b> Water Penetration Resistance Test Pressure: 431 Pa (9 psf)

Product Tested By: Hurricane Test Laboratory, Inc.  
Report No: G118-1108.06 (Spec. 2)  
Expiration Date: **March 31, 2026**

Administrator's Signature: \_\_\_\_\_ 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122