

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013155.01
DATE: 05/04/2016
CERTIFICATION PROGRAM: Structural
COMPANY: MQ Windows
CODE: 1577-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
MQ Windows 50 Rue Brissette Ste-Agathe Des Monts, Quebec J8C 1M4	"MQ Series JS Shaped or Straight Window" In-Swing or Out-Swing Impact Resistant Wood Window Configuration: XX Glazing: Laminate-3/16" Annealed Glass/ 0.090" Interlayer by Eastman Chemical/ 5/32" Heat Strengthened Glass or IG-Laminate-3/16" Annealed Glass/ 0.090" Interlayer by Eastman Chemical/ 5/32" Heat Strengthened Glass/5/32" Tempered Glass Frame: W-1626mm(64") H-2184mm(86") Vent: W-800mm(31.5") H-2105mm(82.88")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: +2777 Pa (58 psf)/-3256 Pa (68 psf) Large Missile Impact Rated Water Penetration Resistance Test Pressure: 417 Pa (8.7 psf)

Product Tested By: Hurricane Test Laboratory, Inc.
Report No: 0118-0204-03 (Spec 1)/0118-0702-99 (Spec 1)/0118-1103-98 (Spec 7)/
0118-1006-98(Spec 7)
Expiration Date: **March 31, 2026**

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122