

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012179-R1
DATE: 11/11/2014
CERTIFICATION PROGRAM: Structural
COMPANY: All Seasons
CODE: 217-1
REVISION DATE: 07/14/2016

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
All Seasons Door & Window, Inc. 28 Edgeboro Road East Brunswick, NJ 08816	Series "A400" Side Load Aluminum Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1422mm(56") H-2311mm(91") Sash: W-1438mm(56.63") H-1137mm(44.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG30 1422 x 2311 (56 x 91)-H Design Pressure: ±1440 Pa (30 psf) Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf)

Product Tested By: National Certified Testing Laboratories, Inc.
Report No: NCTL-110-15106-2
Expiration Date: **July 31, 2026**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. M. D.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122