

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012894-R1  
DATE: 10/08/2015  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 2184-1  
REVISION DATE: 09/09/2016

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Canada</b> <b>7140 40<sup>th</sup> Street, S.E.</b> <b>Calgary, Alberta T2C 2B6</b>	<b>Series "560P"</b> <b>Wood Fixed Window</b> <b>w/Aluminum Cladding</b>  Configuration: O Glazing: Insulating Glass (Annealed)  Frame: W-2060mm(81") H-2060mm(81")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class LC-PG30 2060 x 2060 (81 x 81)-FW</b> <b>Design Pressure: 1440 Pa (30 psf)</b> <b>Negative Design Pressure: 1440 Pa (30 psf)</b> <b>Water Penetration Resistance Test Pressure: 720 Pa (15.0 psf)</b> <b>Canadian Air Infiltration/Exfiltration Level: Fixed</b>

Product Tested By: **Intertek Testing Services NA LTD.**  
Report No: **100240964COQ-003C**  
Expiration Date: **December 31, 2026**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122