

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012997-R1
DATE: 01/25/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 2184-1
REVISION DATE: 09/09/2016

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Canada 7140 40th Street, S.E. Calgary, Alberta T2C 2B6	Series "PH Tech" Vinyl Clad Wood Sliding Door Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1800mm(70.87") H-2080mm(81.89") Panel: W-889mm(35") H-1971mm(77.6")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class R-PG60 1800 x 2080 (71 x 82)-SD Design Pressure: ±2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.0 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Air Ins, Inc.
Report No: AI-03534-A4 Rev 1
Expiration Date: **December 31, 2026**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122