NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI011321.01-R1
DATE: 10/22/2012
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: J-104-3
REVISION DATE: 10/07/2016

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN Doors **3737 Lakesport Drive** **Klamath Falls, OR 97601**	**Series "Energy Saver/Contour" Impact** **Glazed 24 Gauge Steel w/Wood Edge** **Out-Swing Side Hinged Door** **w/Impact Rated Sidelites** Configuration: OXXO Glazing: IG- 1/8" Tempered Glass/Laminate- 1/8" Annealed Glass/0.090" Solutia PVB Interlayer/1/8" Annealed Glass Frame: W-3769mm(148.38") H-2457mm(96.75") Panel: W-908mm(35.75") H-2419mm(95.25") DLO: W-521mm(20.50") H-1997mm(78.63")

SPECIFICATION	PRODUCT RATING
ASTM E283-04/E330-02/E331-00 **AAMA 1304-02** **ASTM E1886-05/1996-05b**	**Positive Design Pressure: 2160 Pa (45 psf)** **Negative Design Pressure Rating: 2160 Pa (45 psf)** **Water Penetration Resistance Test Pressure: 324 Pa(6.75 psf)** **FER-Passed** **Wind Zone 4-Missile Level D** Qualifies Configurations: O/X/OX/XO/OXO/XX/OXX/XXO/OXXO

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3842-2
Expiration Date: **October 31, 2024**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/Fax: (804) 684-5122