

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011929-R5
DATE: 03/04/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Origin
CODE: 1985-1
REVISION DATE: 10/22/2016

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Origin USA, Inc. 771 Commerce Drive, Suite 16 Venice, FL 34292	Series "Easifold 3000" Glazed Aluminum In-Swing & Out-Swing Side-Hinged Doors I/S: w/ or w/o Track Riser O/S: w/Track Riser Configuration: XX Glazing: IG-3/16" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.090" DuPont SG Interlayer/3/16" Heat Strengthened Glass Frame: W-1965mm(77.37") H-2587mm(101.87") Leaf: W-934mm(36.75") H-2438mm(96") DLO: W-762mm(30") H-2286mm(90")

SPECIFICATION	PRODUCT RATING
ASTM E1886-05/E1996-09	Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Wind Zone 4 - Missile Level D

Product Tested By: Architectural Testing Incorporated
Report No: D0972.03-401-44
Expiration Date: December 31, 2026

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122