

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011886.01-R4  
**DATE:** 03/04/2014  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Origin  
**CODE:** 1985-1  
**REVISION DATE:** 10/22/2016

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Origin USA, Inc.</b> <b>771 Commerce Drive, Suite 16</b> <b>Venice, FL 34292</b>	<b>Series "Easifold 3000" Aluminum</b> <b>In-Swing or Out-Swing Folding Door</b> <b>System w/Track Riser &amp;</b> <b>w/ or w/o Hinged Astragal</b>  Configuration: XXXXXXXXX Glazing: IG-3/16" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.090" DuPont SG Interlayer/3/16" Heat Strengthened Glass  Frame: W-7572mm(298.12") H-2587mm(101.87") Leaf: W-934mm(36.75") H-2438mm(96.00") DLO: W-762mm(30.00") H-2286mm(90.00")

SPECIFICATION	PRODUCT RATING
<b>TAS 202-94 (Structural Only)</b> <b>TAS 201/203-94</b>	<b>Design Pressure: 2394 Pa (50 psf)</b> <b>Negative Design Pressure: 2633 Pa (55 psf)</b> <b>Large Missile Impact Rated</b>

Product Tested By: Architectural Testing Incorporated  
Report No: D0973.01-401-18  
Expiration Date: December 31, 2026

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122