

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011509.02-R1
DATE: 03/25/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Loewen
CODE: 1862-1
REVISION DATE: 01/12/2017

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Loewen 77 Highway 52 West Steinbach, Manitoba R5G 1B2	"Aluminum Clad Wood StormForce Awning" Aluminum Clad Wood Awning w/Impact Glazing Configuration: XO Glazing: IG-3.1mm(1/8") Annealed Glass (Exterior)/Laminate- 3.9mm(5/32") Annealed Glass/2.3mm (0.090") SentryGlas® Plus Interlayer/3.9mm(5/32") Annealed Glass (Interior) Frame: W-1500mm(59.06") H-914mm(36") Vent: W-1449mm(57.06") H-864mm(34")

SPECIFICATION	PRODUCT RATING
ASTM E1886-02/05/E1996-02/05	Design Pressure: +70/-70 psf Wind Zone 4-Missile Level D

Product Tested By: Architectural Testing, Inc.
Report No: 92075.02-201-18
Expiration Date: March 31, 2027

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'Shirley' or similar, written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122