NOTICE OF PRODUCT CERTIFICATION I



CERTIFICATION NO: NI013298-R1

DATE: 07/18/2016

CERTIFICATION PROGRAM: Structural

COMPANY: Crystalite

CODE: 1266-1

REVISION DATE: 02/22/2017

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status.

Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Crystalite Skylights	Series "5000"
3307 Cedar Street	Acrylic Domed w/Polycarbonate
Everett, WA 98201	Multiwall Sheet Fixed Skylight
	Configuration: O
	Outer Layer: 0.150" Acrylic Inner Layer: 1" Polycarbonate Multiwall Sheet
	Frame: W-1280mm(50.375") H-2499mm(98.375")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	SKP-PG30 1280 x 2499 (50 x 98)
	Design Pressure: ±1440 Pa (30 psf)
	Positive Structural Test Pressure (Download):
	+2880 Pa (60 psf)
	Negative Structural Test Pressure (Uplift):
	-2160 Pa (45 psf)
	Water Resistance Test Pressure: 290 Pa (6.06 psf)

Product Tested By: National Certified Testing Laboratories

Report No: NCTL-310-5615

Expiration Date: May 31, 2027

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124 Fax: (804) 684-5122