

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011739-R1
DATE: 12/12/2013
CERTIFICATION PROGRAM: Fire
COMPANY: Crystalite
CODE: 1266-1
REVISION DATE: 02/22/2017

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Crystalite Skylights 3307 Cedar Street Everett, WA 98201	Series "1101" Glazed Aluminum Smoke Vent Configuration: XX Outer Dome: 0.150" Nominal Co-Polyester Interior Flat Sheet: 0.100" Nominal Acrylic Frame: W-1334mm (52.50") H-2553mm (100.50") Sash: W-895mm (26.25") H-1505mm (101.25")

SPECIFICATION	PRODUCT RATING
UL 793 (2008)	PASSED

REQUIRED LABEL INFORMATION
CrystaLite, Inc. SERIES 1101 Automatically Operated Vent Risk of Injury Do not place anything on top of this device. Class 60 roof deck Date of manufacture: _____

Product Tested By: National Certified Testing Laboratories
Report No.: NCTL-310-3490
Expiration Date: January 31, 2027

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/ Fax: (804) 684-5122