

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013520
DATE: 02/24/2017
CERTIFICATION PROGRAM: Fire
COMPANY: Dyke Industries
CODE: 452-1
EXPIRATION DATE: 02/28/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Dyke Industries 10500 Northwest 95th Avenue Medley, FL 33178	Simpson Stile & Rail Single Swing Wood Door Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'6" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UL 10b (2009) UL 10c (2009) (2015) (2016) CAN/ULC S104 (2010) (2015) UBC Standard 7-2 (1997)	20 Minute-Positive Pressure With Hose Stream Category B Door-Additional Edge Seal Required (unless specified in individual manufacturer's listing) For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
Intertek Test Report No: 3089369COQ-005, 3137943COQ-003, 3157209COQ-005

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shirley".

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/Fax: (804) 684-5122

