

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013384.03
DATE: 03/22/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	Series "200" Two-Lite Vinyl Fixed Window Configuration: OO Glazing: Insulating Glass (Annealed) Frame: W-2426mm(95.5") H-2426mm(95.5") DLO: W-1129mm(44.44") H-2343mm(92.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CMBSO 1-79/CAWM 301	Class LC-PG35 2426 x 2426 (96 x 96)-FW Design Pressure: ±1680 Pa (35 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-6075
Expiration Date: **December 31, 2020**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122