

NOTICE OF PRODUCT CERTIFICATION



Company: Orepac Building Products
 30160 SW Orepac Avenue
 Wilsonville, OR 97070

Certification No.: NI013710
Certification Date: 01/05/2016
Expiration Date: 01/31/2020

Product: FiberClassic Opaque Fiberglass Door Inswing/Outswing w/ and w/o Sidelites
 Benchmark by Therma-Tru Opaque Fiberglass Door Inswing/Outswing w/ and w/o Sidelites
Specification: ASTM E330/E331/TAS202

The "Notice of Product Certification" is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI's Certified Product Listing at www.Namicertification.com. NAMI's Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Missile Impact Rated	Test Report Number & Comments
X Single	I/S	Opaque	3'0" x 6'8"	+67/-67	No	ETC-01-741-10703.0/L-2097/TTF-253F
X Single	O/S	Opaque	3'0" x 6'8"	+67/-67	No	ETC-01-741-10703.0/L-2097/TTF-254F
XX Double	I/S	Opaque	6'0" x 6'8"	+40/-40	No	ETC-01-741-10703.0/L-2097/TTF-253F Standard Aluminum Astragal
XX Double	O/S	Opaque	6'0" x 6'8"	+40/-40	No	ETC-01-741-10703.0/L-2097/TTF-254F Standard Aluminum Astragal
XX Double	I/S	Opaque	6'0" x 6'8"	+47/-47	No	ETC-01-741-10703.0/L-2097/TTF-253F Coastal Aluminum Astragal
XX Double	O/S	Opaque	6'0" x 6'8"	+47/-47	No	ETC-01-741-10703.0/L-2097/TTF-254F Coastal Aluminum Astragal
OXO/OX/XO Single w/Sidelites	I/S	Opaque Door Glazed Sidelites	5'4" x 6'8"	+40/-40	No	ETC-01-741-10593.0/L-2097/TTF-253F
OXO/OX/XO Single w/Sidelites	O/S	Opaque Door Glazed Sidelites	5'4" x 6'8"	+40/-40	No	ETC-01-741-10593.0/L-2097/TTF-254F
OXXO Double w/Sidelites	I/S	Opaque Door Glazed Sidelites	8'4" x 6'8"	+40/-40	No	ETC-01-741-10593.0/L-2097/TTF-253F Standard Aluminum Astragal
OXXO Double w/Sidelites	O/S	Opaque Door Glazed Sidelites	8'4" x 6'8"	+40/-40	No	ETC-01-741-10593.0/L-2097/TTF-254F Standard Aluminum Astragal
OXXO Double w/Sidelites	I/S	Opaque Door Glazed Sidelites	8'4" x 6'8"	+47/-47	No	ETC-01-741-10593.0/L-2097/TTF-253F Coastal Aluminum Astragal
OXXO Double w/Sidelites	O/S	Opaque Door Glazed Sidelites	8'4" x 6'8"	+47/-47	No	ETC-01-741-10593.0/L-2097/TTF-254F Coastal Aluminum Astragal

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
 Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: _____

A handwritten signature in black ink, appearing to be 'S.M.', is written over the signature line.