

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012031.02-R1
DATE: 06/22/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Kalwall
CODE: 322-1
REVISION DATE: 09/07/2017

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Kalwall Corporation 1111 Candia Road Manchester, NH 03105	Series "Awning" Project-Out-At-Bottom Awning Window Configuration: X Glazing: IG-Ext-6mm (0.220") Tempered Glass/ Interior-Laminate-4mm (0.155") Heat Strengthened Glass/0.090" DuPont Sentry Glass Plus Interlayer/ 4mm (0.155") Heat Strengthened Glass Frame: W-1524mm(60") W-914mm(36") DLO: W-1457mm(57.38") W-848mm(33.38")

SPECIFICATION	PRODUCT RATING
ASTM E1886-04/05 ASTM E1996-02/04/06/09/12a	Design Pressure: ±3830 Pa (80 psf) Wind Zone 4-Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-16372-2
Expiration Date: December 31, 2027

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122