NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012031-R2

DATE: 06/22/2014

CERTIFICATION PROGRAM: Structural

COMPANY: Kalwall

CODE: 322-1

REVISION DATE: 09/07/2017

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status.

Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Kalwall Corporation	Series "Awning"
1111 Candia Road	Project-Out-At-Bottom Awning Window
Manchester, NH 03105	Configuration: X
	Glazing: IG-Ext-6mm (0.220") Tempered Glass/ Interior-Laminate-4mm (0.155") Heat Strengthened Glass/0.090" DuPont Sentry Glass Plus Interlayer/ 4mm (0.155") Heat Strengthened Glass
	Frame: W-1524mm(60") W-914mm(36")
	DLO: W-1457mm(57.38") W-848mm(33.38")

SPECIFICATION	PRODUCT RATING
AAMA 506-06/08	Design Pressure: ±3352 Pa (70 psf)
ASTM E1886-02/04/15/13a	Wind Zone 4-Missile Level D
ASTM E1996-02/04/06/09/12a	Large Missile Impact Rated
TAS 201/202/203-94	Class AW-PG70 1524 x 914 (60 x 36)-AP
AAMA/WDMA/CSA 101/I.S.2/A440-08	AP-AW70 1524 x 914 (60 x 36)
AAMA/WDMA/CSA 101/I.S.2/A440-05	Water Penetration Resistance Test Pressure: 720 Pa(15 psf)

Product Tested By: National Certified Testing Laboratories

Report No: NCTL-110-16858-1/NCTL-110-16370-1/NCTL-110-16372-1

Expiration Date: **December 31, 2027**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124/Fax: (804) 684-5122