

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010030-R3  
DATE: 09/29/2009  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ameritech  
CODE: 474-1  
REVISION DATE: 11/27/2017

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ameritech Millwork, LP.</b> <b>2300 West Marshall Drive</b> <b>Grand Prairie, TX 75051</b>	<b>Jeld-Wen's "Steel Wood-Edge" Double</b> <b>In-Swing/Out-Swing Entry Doors</b> <b>w/ODL Impact Glass and Endura Ultimate</b> <b>Hurricane Astragal</b>  Configuration: XX Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" Solutia PVB Interlayer/1/8" Annealed Glass  Frame: W-6'2" Panel: W-3'1" DLO: W-1'10"  H-6'11" H-6'7" H-5'4"

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/2013-94</b>	<b>Design Pressure: +60/-60 psf</b> <b>Large Missile Impact Rated</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3195-1 (Structural/Impact)  
Expiration Date: **September 30, 2026**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

**NATIONAL ACCREDITATION AND**  
**MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122