

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI010585-R2  
**DATE:** 04/12/2011  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Milliken  
**CODE:** M-994-1  
**REVISION DATE:** 12/12/2017

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Milliken Millwork, Inc.</b> <b>6361 Sterling Drive</b> <b>PO Box 667</b> <b>Sterling Heights, MI 48311</b>	<b>Series "Single Door with Sidelites"</b> <b>Full Lite In-Swing Fiberglass Door</b> <b>w/Wood Frame Assembly</b>  Configuration: OXO Glazing: Insulating Glass (Tempered)  Frame: W-1727mm (68.00") H-2064mm (81.25") Panel: W-908mm (35.75") H-2000mm (78.75") SL: W-352mm (13.88") H-2000mm (78.75")  STP: Pos+3591 Pa (75.0 psf) Neg-3591 Pa (75.0 psf)

SPECIFICATION	PRODUCT RATING
<b>ASTM E283-04/E330-10/E331-09</b>	<b>Design Pressure: +50/-50 psf</b> <b>Canadian Air Infiltration/Exfiltration Level = A3</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-13518-2/NCTL-110-10570-5  
Expiration Date: December 31, 2027

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122