

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011120-R2
DATE: 05/28/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Milliken
CODE: 997-1
REVISION DATE: 12/12/2017

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Milliken Millwork, Inc. 172 Plummer Road Sidman, PA 15955	"Single Door w/Sidelites and Transom" Inswing Fiberglass Opaque Door Composite/Vinyl Clad Frame Assembly w/Sidelites & Transom Configuration: O/OXO Glazing: Insulating Glass (Tempered) Frame: W-1740mm(68.5") H-2350mm(92.5") Panel: W-909mm(35.75") H-2000mm(78.75") SL: W-352mm(13.87") H-2016mm(79.37") TR: W-279mm(11") H-2350mm(92.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CSA A440S1-09	Class R-PG50 1740 x 2350 (69 x 93)-LWSHD LWSHD-R50 1740 x 2350 (69 x 93) Design Pressure: 2400 Pa (50 psf) Canadian Air Infiltration/Exfiltration Level = A2

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-14666-1
Expiration Date: December 31, 2027

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shelby", written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122