

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013936  
**DATE:** 01/22/2018  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Pacifica Vinyl  
**CODE:** 1191-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Pacifica Vinyl Windows</b> <b>12301 Woodruff Avenue</b> <b>Downey, CA 90241</b>	<b>Series "4400/4450/4490/4461"</b> <b>Vinyl Single Hung Window</b>  Configuration: O/X Glazing: Insulated Glass (Annealed)  Frame: W-1207mm(47.5") H-2426mm(95.5") Sash: W-1149mm(45.25") H-1197mm(47.13") DLO: W-1067mm(42") H-1114mm(43.88")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class LC-PG25 1207 x 2426 (48 x 96)-H</b> <b>Design Pressure: ±1200 Pa (25 psf)</b> <b>Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)</b>

Product Tested By: Architectural Testing Incorporated  
Report No: E8498.02-501-47  
Expiration Date: **September 30, 2020**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122