

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013938.01
DATE: 01/22/2018
CERTIFICATION PROGRAM: Structural
COMPANY: Pacifica Vinyl
CODE: 1191-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Pacifica Vinyl Windows 12301 Woodruff Avenue Downey, CA 90241	Series "Royal Series 9100/9150/9190" Vinyl Sliding Glass Door Configuration: XO Glazing: Insulated Glass (Tempered) Frame: W-1829mm(72") H-2032mm(80") Panel: W-949mm(37.38") H-1981mm(78") DLO: W-829mm(35.63") H-1861mm(73.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG25 1829 x 2032 (72 x 80)-SD Design Pressure: ±1200 Pa (25 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Architectural Testing Incorporated
Report No: F6516.03-501-47
Expiration Date: March 31, 2020

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122