## NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012008-R1

> **DATE:** 06/09/2014

**CERTIFICATION PROGRAM:** Structural

> **COMPANY:** Hope's

**CODE:** 656-1

**REVISION DATE:** 04/09/2018

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim Please review and advise NAMI if any corrections are required to this document. certification status.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Hope's Windows, Inc.	Series "SS30"
84 Hopkins Avenue	Stainless Steel Direct Set
Jamestown, NY 14702	Impact Rated Fixed Windows
	Configuration: O/O Glazing: Detention Glass by Century Glass- 1/4" Chemically Strengthened Glass/5mm Lexan Polycarbonate/5mm Lexan Polycarbonate /1/4" Chemically Strengthened Glass
	Overall: W-3004mm(118.25") H-2438mm(96")
	Individual: W-1524mm(60") H-2438mm(96")
	DLO: W-1371mm(54") H-2286mm(90")

SPECIFICATION	PRODUCT RATING
AAMA 450-10 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-97/03/04/05/13/13a ASTM E1996-02/04/05/05b/06/09	Mulled Fenestration Rating: CW80 Applied Rating: CW80 Individiual Rating: Class CW-PG80 1524 x 2438 (60 x 96)-FW Class CW-PG80 3004 x 2438 (118 x 96)-FW Design Pressure: 3840 Pa (80 psf) Wind Zone 4-Missile Level E Water Penetration Resistance Test Pressure: 580 Pa(12.11 psf) Canadian Air Infiltration/Exfiltration Rating: Fixed

Product Tested By: Element Materials Technology

Report No: ESP016682P-1556 Expiration Date:

May 31, 2028

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway **Hayes, VA 23072** 

Tel: (804) 684-5124/Fax: (804) 684-5122