

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014032
DATE: 04/30/2018
CERTIFICATION PROGRAM: Fire
COMPANY: Orepac
CODE: 1234-1
EXPIRATION DATE: 04/30/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Orepac Building Products, Inc. 30160 SW Orepac Avenue Wilsonville, OR 97070	FyreWerks FC-20 20 Minute Positive Pressure Glazed Radius Top Side-Hinged Door Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 6'8" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
UL 10(b) (2009) UBC Standard 7-4 (1994/1997) UL 10(c) (2009) NFPA 252 (2008/2012)	20 Minute-Positive Pressure Without Hose Stream Category A Door-No Additional Edge Seal Required For Use in Category C Frame <small>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</small>

TEST REPORT
Intertek Test Report No: 100846880COQ-007

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shelby".

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122