

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012158-R1  
DATE: 10/31/2014  
CERTIFICATION PROGRAM: Structural  
COMPANY: Piva  
CODE: 1722-1  
REVISION DATE: 06/12/2018

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS   | PRODUCT DESCRIPTION   |
|--|---|
| <b>Piva Group Spa</b><br><b>Via Roma, 139</b><br><b>Roncanova Di Gazzo Veronese</b><br><b>Verona, Italy 18-37122</b> | <b>"Piva 75 Tilt and Turn<br/>with Rolling Shutter"</b><br><b>Vinyl Dual Action Window</b><br><br>Configuration: X<br>Glazing: Insulating Glass (Annealed)<br><br>Frame: W-1200mm(47.25") H-2200mm(86.25")<br>Panel: W-1101mm(43.37") H-1847mm(72.75")<br>DLO: W-930mm(36.62") H-1679mm(66.12") |

| SPECIFICATION  | PRODUCT RATING  |
|--|---|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b><br><b>CSA A440S1-09</b> | <b>Class LC-PG60 1200 x 2200 (47 x 86)-DAW</b><br><b>DAW-LC60 1200 x 2200 (47 x 86)</b><br><b>Design Pressure: 2880 Pa (60 psf)</b><br><b>Negative Design Pressure: 2880 Pa (60 psf)</b><br><b>Water Penetration Resistance Test Pressure: 720 (15.04 psf)</b><br><b>Canadian Air Infiltration/Exfiltration Level: A3</b> |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-16277-1  
Expiration Date: October 31, 2026

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122