

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012159-R1
DATE: 10/15/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Piva
CODE: 1722-1
REVISION DATE: 06/12/2018

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Piva Group Spa Via Roma, 139 Roncanova Di Gazzo Veronese Verona, Italy 18-37122	"PSV 7000" Vinyl Tilt Double Hung Window w/Standard & J-Channel Frame Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1118mm(44.00") H-1905mm(75.00") Sash: W-1022mm(40.25") H-1010mm(39.75") DLO: W-946mm(37.25") H-933mm(36.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 CSA A440S1-09	Class R-PG40 1118 x 1905 (44 x 75)-H H-R40 1118 x 1905 (44 x 75) Design Pressure: 1920 Pa (40 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 360 (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-16145-1
Expiration Date: October 31, 2026

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122