

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	NI014217
DATE:	09/18/2018
CERTIFICATION PROGRAM:	Fire
COMPANY:	Dyke Industries
CODE:	452-1
EXPIRATION DATE:	09/30/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Dyke Industries 10500 Northwest 95th Avenue Medley, FL 33178</p>	<p style="text-align: center;">Crest Doors 20 Minute Positive Pressure Particleboard Core/Wood Veneer Side-Hinged Door Assembly</p> <p style="text-align: center;">Manufacturer Specific Fire Doors for Single & Double Swing Installation in 20 Minute Locations</p> <p style="text-align: center;">1/2" Minimum Latch Throw Single & Double Swing Only</p> <p style="text-align: center;">Single Maximum Size: 4'0" x 9'0" Double Maximum Size: 8'0" x 9'0" Minimum Thickness: 1-3/4"</p>

SPECIFICATION	PRODUCT RATING
<p>UBC-7-2-97 UL 10C (1998)(2009) NFPA 252 (1995)(2008)</p>	<p style="text-align: center;">20 Minute-Positive Pressure w/o Hose Stream Category A Door-No Additional Edge Seal Required Category B Door-Additional Edge Seal Required For Use in Category C Frame</p> <p style="text-align: center;"><small>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</small></p>

TEST REPORT
<p>Warnock Hershey Test Report No: WHI-495-1367</p>

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122