NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI012244.02-R1**
DATE:	**06/14/2015**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Quaker**
CODE:	**031-1**
REVISION DATE:	**10/22/2018**

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products **504 Highway 63 South** **Freeburg, MO 65035**	**Series "E600/T600"** **Aluminum Mulled Fixed Twin Window** Configuration: O/O Glazing: Insulating Glass (Annealed) Frame: W-2134mm(84") H-1829mm(72") DLO: W-826mm(32.5") H-2032mm(80")

SPECIFICATION	PRODUCT RATING
AAMA 450-10 **AAMA/WDMA/CSA 101/I.S.2/A440-08**	**Overall Assembly Rating: AW40** **Mulled Assembly Rating: AW40** **Individual Product Rating:** **AW-PG50 1524 x 2515 (60 x 99)-FW**

Product Tested By: Architectural Testing, Inc.
Report No: E4594.01-801-47/E1284.01-801-47
Expiration Date: **January 31, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122