

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014276.01  
DATE: 12/05/2018  
CERTIFICATION PROGRAM: Structural  
COMPANY: Dunbarton  
CODE: 1319-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Dunbarton Corporation</b> <b>555 Benton Industrial Road</b> <b>Camden, TN 38320</b>	<b>"Rediflex Steel Frame</b> <b>w/Opaque Outswing Fiberglass Door</b>  Configuration: X  Frame: W-997mm(39.25") H-2076mm(81.75") Panel: W-909mm(35.75") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
<b>AAMA 1702.2-95</b> <b>Federal Manufactured Home Construction</b> <b>&amp; Safety Standard 3280.305</b> (applicable sections)	<b>Manufactured Housing-Passed</b> <b>Wind Zone III</b> <b>Design Wind Pressure Rating:</b> <b>+58/-58 psf</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 01092227  
Expiration Date: November 30, 2022

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shi", written over a horizontal line.

**NATIONAL ACCREDITATION AND**  
**MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122