

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014278  
**DATE:** 12/10/2018  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Titan Glass  
**CODE:** 2447-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Titan Glass &amp; Aluminum, LLC</b> <b>450 West 27th Avenue</b> <b>Hialeah, FL 33010</b>	<b>Series "3070"</b> <b>Aluminum Fixed Window Assembly</b>  Configuration: OOO Glazing: Monolithic-1/4" Heat Strengthened Glass/0.060" Kuraray Trosifol PVB Interlayer/1/4" Heat Strengthened Glass  Frame: W-4648mm(183")      H-3048mm(120") DLO: W-1451mm(57.13")      H-2896mm(114")

SPECIFICATION	PRODUCT RATING
<b>TAS 202-94</b> <b>(Structural Only)</b> <b>TAS 201/203-94</b>	<b>Design Pressure: ±6224 Pa (130 psf)</b> <b>Small Missile Impact Rated</b>

Product Tested By: Fenestration Testing Laboratory, Inc.  
Report No: FTL 10417  
Expiration Date: November 30, 2022

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122