

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014288
DATE: 12/20/2018
CERTIFICATION PROGRAM: Fire
COMPANY: Trimco Millwork
CODE: 868-1
EXPIRATION DATE: 12/31/2022

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Trimco Millwork 1835 Commerce Avenue Boise, ID 83715	20 Minute Positive Pressure Steel Fire Door Assemblies w/o Hose Stream Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 3'0" x 7'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
NFPA 252 (1999) UL 10C (1998) UL 10B (1997) UBC Standard 7-2 (1997)	20 Minute-Positive Pressure Without Hose Stream Category B Door-Additional Edge Seal Required (unless specified in individual manufacturer's listing) For Use in Category C Frame (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT

Intertek Test Report No: 3042535-1, 3042535-2
NAMI Waiver of Retest: W-1653

A handwritten signature in black ink, appearing to be 'M.D.', is written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/Fax: (804) 684-5122