

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014297  
DATE: 01/08/2019  
CERTIFICATION PROGRAM: Fire  
COMPANY: Horizon Supply  
CODE: 2504-1  
EXPIRATION DATE: 01/31/2023

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Horizon Supply, LLC</b> <b>19998 Monte Way</b> <b>Caldwell, ID 83607</b>	<b>Lynden 20 Minute L20 MDF-R</b> <b>Fire Door Assembly</b>  Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single Swing Only  <b>Maximum Size: 3'0" x 7'0"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2008)(2012)</b> <b>UL 10C (2001)(2009)</b> <b>UL 10B (2008)(2009)</b> <b>UBC Standard 7-2 (1997)</b> <b>CAN/ULC S104 (2010)</b>	<b>20 Minute-Positive Pressure</b> <b>With Hose Stream</b> <b>Category B Door-Additional Edge Seal Required</b> (unless specified in individual manufacturer's listing) <b>For Use in ANSI-A155/UL-63 Steel Frame</b> (or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)

TEST REPORT
<b>Intertek Test Report No: 101318303COQ-002/101503991COQ-001</b>

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122