

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014298  
**DATE:** 01/08/2019  
**CERTIFICATION PROGRAM:** Fire  
**COMPANY:** Horizon Supply  
**CODE:** 2504-1  
**EXPIRATION DATE:** 01/31/2023

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Horizon Supply, LLC</b>  <b>19998 Monte Way</b>  <b>Caldwell, ID 83607</b>	<p style="text-align: center;"><b>Lynden 20 Minute L20SP</b></p> <p style="text-align: center;"><b>Wood Core Fire Door Assembly</b></p> <p style="text-align: center;">Manufacturer Specific Fire Doors for Single and Double Swing Installation in 20 Minute Locations</p> <p style="text-align: center;">1/2" Minimum Latch Throw for Singles 3/4" Minimum Latch Throw for Double Single &amp; Double Swing Only</p> <p style="text-align: center;"><b>Single Maximum Size: 4'0" x 9'0"</b>  <b>Single Maximum Size: 3'6" x 10'0"</b>  <b>Double Maximum Size: 8'0" x 9'0"</b>  <b>Double Egress Maximum Size: 8'0" x 8'0"</b>  <b>Dutch Door: 4'0" x 8'0"</b>  <b>Door w/Transom Maximum Size: 4'0" x 10'0"</b>  <b>Transom Maximum Size: 3'0" x 3'4"</b>  <b>Minimum Thickness: 1-3/4"</b></p>

SPECIFICATION	PRODUCT RATING
<p style="text-align: center;"> <b>NFPA 252 (2008)(2012)</b>  <b>UL 10C (2001)(2009)(2016)</b>  <b>UL 10B (2008)(2009)</b>  <b>UBC Standard 7-2 (1994)(1997)(2015)</b>  <b>CAN/ULC S104 (1985)(2010)</b>  <b>CSFM 43.7</b> </p>	<p style="text-align: center;"> <b>20 Minute-Positive Pressure</b>  <b>With Hose Stream</b>  <b>Category B Door-Additional Edge Seal Required</b>  <small>(unless specified in individual manufacturer's listing)</small>  <b>For Use in Category C-Standard Frame</b>  <small>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</small> </p>

TEST REPORT
<b>Intertek Test Report No: 491-7972/3052139/3060684/3075954/3157236/103140421</b>

Administrator's Signature: \_\_\_\_\_ *AKD*

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122

