


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014321
DATE: 01/17/2019
CERTIFICATION PROGRAM: Fire
COMPANY: EL & EL Wood
CODE: 2195-1
EXPIRATION DATE: 01/31/2023

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
EL & EL Wood Products, Inc. 13855 Ramona Avenue Chino, CA 91710	"Simpson Fire Rated Panel" Proprietary Fire Door Panel Manufacturer Specific Fire Doors for Single Swing Installation in 20 Minute Locations 1/2" Minimum Latch Throw Single or Double Swing Single Maximum Size: 3'6" x 8'0" Double Maximum Size: 7'0" x 8'0" Minimum Thickness: 1-3/4"

SPECIFICATION	PRODUCT RATING
ASTM E152-81a CSFM 43.7 UBC 7-2 (1994) UL 10B (1997)(2009) NFPA 252 (1995)	20 Minute-Neutral Pressure Without Hose Stream

TEST REPORT
Intertek Test Report No: WHI-495-0435, WHI-495-0474, WHI-495-PSV-0934, WHI-495-PSV-1255, WHI-495-PSV-1296, 3135741COQ-003

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122